



#### LATERAL SPECIFICATIONS

1. 6" DIAMETER IS THE MINIMUM SIZE. LARGER SIZES WILL BE SPECIFIED BY THE AUTHORITY WHEN THE AMOUNT OF FLOW WARRANTS IT.
2. SLOPE SHALL BE 1/4" PER FOOT UNLESS APPROVED BY THE AUTHORITY.
3. CLEANOUTS MUST BE INSTALLED EVERY 50' ON 4" PIPE AND EVERY 100' ON 6" PIPE.
4. LATERALS SHALL BE LAID ON SAND/SCREENINGS.
5. CLEANOUT TERMINAL(S) SHALL HAVE TREATMENT AS RESPECTIVE LOCATION WARRANTS. (SEE DWG. NO'S.
6. ALL PIPING MATERIALS FOR GRAVITY APPLICATIONS SHALL BE SCH 40 PVC. ANSI/ASTM D2665

#### INSPECTION

1. WORK MUST BE INSPECTED AND TESTED BEFORE BACKFILLING
2. THERE IS NO CHARGE FOR ONE-TIME INSPECTED UNLESS THE LATERAL IS LONGER THAN 150' AND/OR IF THE PIPE IS MORE THAN 4" IN DIAMETER
3. INSPECTION REQUIRING MORE THAN ONE VISIT TO THE SITE WILL BE BILLED AT A RATE IN EFFECT AT THE TIME OF INSPECTION.